



**"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"**

 DELHI JAL BOARD	<b>DELHI JAL BOARD ;( GOVT. OF N.C.T. DELHI )</b> <b>QUALITY CONTROL LABORATORY,</b> <b>WATER TREATMENT PLANT HAIDERPUR,</b> <b>DELHI-110085.</b>  <b>(ISO Certified 9001:2015)</b>	 भारतीय मानक बोर्ड BUREAU OF INDIAN STANDARDS
--	--	--

Sample collected from drinking point in the premises of **Jeevan Public Sr. Sec. School, Pratap Vihar Part-II Kirari Extn. New Delhi - 110086** vide challan no. 78 dated 20.06.2024.

S. No.	PARAMETERS	UNITS	Limit as per B.I.S.10500:2012		S1
			Acceptable	Permissible	
1.	Date of collection	--	---	---	21.06.2024
2.	Date of Analysis	--	---	---	23.06.2024
3.	Colour	C.U.	5	15	<1 C.U.
4.	Odour	--	Agreeable		Agreeable
5.	Turbidity	N.T.U	1.0	5.0	2.02
6.	pH value	--	6.5 to 8.5	N.R.	7.5
7.	Electrical Conductivity	µmhos/cm	----	----	185.0
8.	Total Dissolved Solid	(mg/l)	500	2000	120.25
<b>CHEMICAL EXAMINATION</b>					
9.	Phenolphthalein Alkalinity	(mg/l)	----	----	Nil
10.	Total Alkalinity	(mg/l)	200	600	60.0
11.	Total Hardness	(mg/l)	200	600	94.0
12.	Calcium Hardness	(mg/l)	200	600	70.0
13.	Magnesium Hardness	(mg/l)	200	600	24.0
14.	Calcium as Ca	(mg/l)	75	200	28.0
15.	Magnesium as mg	(mg/l)	30	100	5.76
16.	Ammonia (as NH <sub>3</sub> -N)	(mg/l)	0.5	N.R.	ND
17.	Nitrite -Nitrogen (N)	(mg/l)	---	---	ND
18.	Nitrate (NO <sub>3</sub> )	(mg/l)	45	N.R.	2.12
19.	Sulphate (SO <sub>4</sub> )	(mg/l)	200	400	31.90
20.	Chloride (Cl)	(mg/l)	250	1000	12.0
21.	Iron (Fe)	(mg/l)	1.0	N.R.	0.02
22.	Fluorides (F)	(mg/l)	1.0	1.5	0.34
23.	Cyanides (CN)	(mg/l)	0.05	N.R.	ND
24.	Residual Chlorine	(mg/l)	0.2	1.0	0.52
<b>BACTERIOLOGICAL EXAMINATION</b>					
25.	Coli form per 100 ml at 37°C	MPN/100 mL	0		0

**Remarks:** On the basis of above tested parameters, water sample (S1) confirms to drinking water specification I.S.10500:2012 and may be used for drinking purpose.

*[Signature]*  
24/6/24  
Asstt. Chemist


*[Signature]*  
25.6.24  
Chemist/Bacteriologist

*[Signature]*  
A.C.W.A. (HP- I)

*[Signature]*  
C.W.A. (W&S)-II

*[Signature]*  
**MANAGER**  
**JEEVAN PUBLIC SCHOOL,**  
**PRATAP VIHAR PART-II**  
**KIRARI EXTN., DELHI-86**

**Principal**  
**Jeevan Public School**  
**Pratap Vihar-II, Delhi-110086**



MUNICIPAL CORPORATION OF DELHI  
OFFICE OF DY. HEALTH OFFICER  
PUBLIC HEALTH DEPARTMENT: ROHINI ZONE  
SECTOR: 5: ROHINI: DELHI: 110085

No. DHO/RZ/2024/198

Dated 11/06/2024

**SCHOOL HEALTH CERTIFICATE**

It is certified that an inspection team headed Asst. Public health Inspector from Public Health department Rohini Zone inspected the **Jeevan Public Sr. Sec. School** situated at **Pratap Vihar Part-II, Kirari Extn. Delhi-110086** and found that the **Jeevan Public Sr. Sec. School** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus.

The above certificate is valid for the one year from date of issue.

Dy. Health Office

Rohini Zone

Principal

**Jeevan Public Sr. Sec. School**  
**Pratap Vihar Part-II, Kirari Extn.**  
**Delhi-110086**

  
MANAGER  
JEEVAN PUBLIC SCHOOL  
PRATAP VIHAR PART-II  
KIRARI EXTN., DELHI-86

  
Principal  
Jeevan Public School  
Pratap Vihar-II, Delhi-110086